

**American River Flood Control District  
Central Valley Flood Protection Board Permit Application  
Sump 155 Modifications (City of Sacramento)  
Staff Report**

**Discussion:**

The City of Sacramento submitted this encroachment permit application to modify facilities at their Sump 155 Pump Station. The work proposed is to remove and replace approximately 360 ft of two (2) 36" welded steel pipes. Remove and replace approximately 120 ft of one (1) 42" Corrugated Metal Pipe.

Sump 155 is located adjacent to the American River South Levee and just north of the H Street Bridge in River Park.

These modifications are required to upgrade the pipe outfall system at the pump station. The current system does not meet modern U.S. Army Corps of Engineers' standards. The USACE now requires that all pressurized pipes cross the levee at or above the 200-year flood elevation for the adjacent channel and that the pipes each have a positive closure device (shut-off valve) at the waterside crown hinge point. The proposed work will upgrade the facility to meet all State and Federal requirements.

Once the work is complete, it is not anticipated that this work will pose significant operations and maintenance impacts to the District. There will be temporary loss of access and thoroughfare for the District during construction.

**Recommendation:**

The General Manager recommends that the Board of Trustees endorse the CVFPB permit application.

**APPLICATION FOR A CENTRAL VALLEY FLOOD PROTECTION BOARD  
ENCROACHMENT PERMIT**

Application No. \_\_\_\_\_  
(For Office Use Only)

1. Description of proposed work being specific to include all items that will be covered under the issued permit.  
Sump 155 Modifications: Remove and replace approximately 360 ft of two (2) 36" welded steel pipes. Remove and replace approximately 120 ft of one (1) 42" Corrugated Metal Pipe.

2. Project Location: Sacramento County, in Section See Attachment A  
Township: See Attachment A (N) (S), Range: See Attachment A (E) (W), M. D. B. & M.  
Latitude: 38.57020 Longitude: -121.42420  
Stream: American River, Levee: Left Bank Designated Floodway: American River  
APN: See Attachment A

3. Raymond Kong, PE of 1395 35th Ave  
Name of Applicant / Land Owner Address  
Sacramento CA 95822 (916) 808-1435  
City State Zip Code Telephone Number  
RKong@cityofsacramento.org  
E-mail

4. Ashley Smith, PE of Peterson Brustad Inc.  
Name of Applicant's Representative Company  
Folsom CA 95630 (916) 608-2212 x 123  
City State Zip Code Telephone Number  
asmith@pbieng.com  
E-mail

5. Endorsement of the proposed project from the Local Maintaining Agency (LMA):

We, the Trustees of American River Flood Control District approve this plan, subject to the following conditions:  
Name of LMA

Conditions listed on back of this form  Conditions Attached  No Conditions

\_\_\_\_\_  
Trustee Date Trustee Date  
\_\_\_\_\_  
Trustee Date Trustee Date



**Attachment A – Summary of Proposed Work**

**CITY OF SACRAMENTO PUMP OUTFALLS PROJECT:  
CENTRAL VALLEY FLOOD PROTECTION BOARD ENCROACHMENT PERMIT**

**SUMMARY OF PROPOSED WORK**

September 15, 2020

**INTRODUCTION**

As mandated by the Sacramento Area Flood Control Agency (SAFCA) and the U.S. Army Corps of Engineers (USACE), sump station outfalls that penetrate and cross major levees are inspected on a 5-year cycle. The project entails the complete replacement of the pump discharge for three (3) drainage sump station facilities and partial replacement of the pump discharge pipe for five (5) drainage sump station facilities. The following information pertains to a complete replacement sump (Sump 155) that will need an updated Encroachment Permit from the CVFPB.

**APN Parcels**

Sump	Existing Permit #	APN
155	N/A	005-0010-024-0000, 005-0010-025-0000

**ADJACENT PARCELS**

All of the parcels adjacent to the Sump to be modified are listed in the table presented below as provided by the Sacramento County Assessor's Office.

APN	Address	Owner	Owner Address	City	Zip
005-0010-005-0000	SEWARD CT	STATE OF CALIFORNIA	N/A	SACRAMENTO	95826
005-0203-002-0000	250 SANDBURG DR	TIMOTHY C JOHNSON	250 SANDBURG DR	SACRAMENTO	95819
005-0203-003-0000	240 SANDBURG DR	MICHAEL L CHIECHI	240 SANDBURG DR	SACRAMENTO	95819
005-0203-004-0000	230 SANDBURG DR	OBRIEN FAMILY TRUST	230 SANDBURG DR	SACRAMENTO	95819
005-0203-005-0000	220 SANDBURG DR	SURVIVORS TRUST	220 SANDBURG DR	SACRAMENTO	95819
005-0203-006-0000	210 SANDBURG DR	DONALD T TERRELL	210 SANDBURG DR	SACRAMENTO	95819

005-0203-014-0000	E SANDBURG DR	AMERICAN RIVER FLOOD CONTROL DIST	165 COMMERCE CIR UNIT D	SACRAMENTO	95815
005-0203-018-0000	6005 CAMELLIA AVE	SEAN RANNEY	PO BOX 191334	SACRAMENTO	95819
005-0233-003-0000	6025 CAMELLIA AVE	CITY OF SACRAMENTO	915 I ST FL5	SACRAMENTO	95814
005-0233-004-0000	6009 CAMELLIA AVE	SCOTTISH GARDENS LLC	5813 W 2 <sup>ND</sup> ST	RIO LINDA	95673
005-0233-006-0000	H ST	AMERICAN RIVER FLOOD CONTROL DIST	185 COMMERCE CIR	SACRAMENTO	95815

### **TOWNSHIP AND RANGE INFORMATION**

Note that gaps exist in Townships and Ranges within the project area. Land not covered by T9N R5E has been in private ownership since before California joined the United States and therefore is not part of the Township and Range system, which was a survey of federal lands.

### **SITE PHOTOGRAPHS**

Attached to this Summary of Proposed Work are photographs showing levee and channel areas representative of proposed work sites.



Figure 1: View of pump station





Figure 2: View from waterside TOE of Levee facing Levee crest (upstream)





Figure 3: View from waterside slope of levee facing downstream towards American River








Figure 4: View of outfall structure with flapgates at the waterside slope of Levee

**Attachment B – Plan Sheets**

*(Excerpt from larger plan set for Pump Outfalls Replacement Project – B)*





PN: W14130615

DATE: 09/19/20  
 DRAWN BY: E. JUEA  
 CHECKED BY: A. SMITH  
 R.C.E. NO. 08502  
 DATE: 03/31/21

65% SUBMITTAL  
 PUMP OUTFALLS REPLACEMENT PROJECT - B  
 SUMP 089 AND 155  
 STAGING AREA



CITY OF SACRAMENTO  
 DEPARTMENT OF UTILITIES

FIELD BOOK  
 0000  
 SCALE:  
 H. \_IN\_ / V. \_IN\_

BENCH MARK  
 ELEV. \_\_\_\_\_  
 DESCRIPTION: \_\_\_\_\_



REVISIONS  
 DESCRIPTION DATE BY

ON ORIGINAL SCALE  
 DRAWING ADJUSTS  
 DIMENSIONS  
 IF THIS DOES NOT  
 SCALE AT 1"

1"  
 SCALE AT 1"


DATE: 09/19/20  
 DRAWN BY: E. JUEA  
 CHECKED BY: A. SMITH  
 R.C.E. NO. 08502  
 DATE: 03/31/21

PN: W14130615  
 PUMP OUTFALLS REPLACEMENT PROJECT



PN: W14130615  
 65% SUBMITTAL

IMPROVEMENT PLANS FOR  
**PUMP OUTFALLS REPLACEMENT PROJECT - B**  
 SUMP 155  
 DEMO PLAN



**CITY OF SACRAMENTO**  
 DEPARTMENT OF UTILITIES

DESIGNED BY: B. JENSEN  
 DRAWN BY: E. JUEGA  
 CHECKED BY: A. SMITH

DATE: 09/15/20  
 DATE: 03/31/21  
 R.C.E. NO. 090849  
 R.C.E. NO. 08652

FIELD BOOK  
 0000

SCALE:  
 H. 1"=10'  
 V. 1"=5'


ON ORIGINAL SCALE  
 DRAWING ADJUST  
 IF THIS DOES NOT  
 SCALE AT 1"

BENCH MARK  
 DESCRIPTION:  
 MONUMENT, IRL & WISER

ELEV. 36.95

REVISIONS	DATE	BY





HOR SCALE: 1"=10'  
 10 5 0 0  
 5 2.5 0 0  
 VERT SCALE: 1"=5'

PN: W14130615  
 65% SUBMITTAL

IMPROVEMENT PLANS FOR  
**PUMP OUTFALLS REPLACEMENT PROJECT - B**  
**SUMP 155**  
**SITE PLAN**



**CITY OF SACRAMENTO**  
**DEPARTMENT OF UTILITIES**

DESIGNED BY: E. JUEVA  
 DRAWN BY: B. JENSEN  
 CHECKED BY: A. SMITH

DATE: 09/15/20  
 DATE: 03/21/22  
 DATE: 03/31/21

R.C.E. NO. 09049  
 R.C.E. NO. 08502

FIELD BOOK  
 0000



SCALE:  
 H. 1"=10'  
 V. 1"=5'

ON ORIGINAL SCALE  
 DRAWING ADJUST  
 IF THIS DOES NOT  
 SCALE AT 1"


BENCH MARK  
 DESCRIPTION:  
 MONUMENT, IRL & WISER

ELEV. 36.95



REVISIONS	DATE	BY




- NOTES:
- REMOVE AND DISPOSE OF EXISTING 36" WSP AND APPURTENANCES FROM STA -0+64.5 TO STA 1+14.4 PER DETAIL 2/C19
  - INSTALL 36" WSP FROM STA -0+64.5 TO STA 0+68.7 PER DETAIL 3/C19
  - INSTALL 36" FL x FL KNEE GATE VALVE
  - INSTALL COMBINATION ANTI-SIPHON AND AIR RELIEF VALVE PER DETAIL 3/C15
  - INSTALL ANTI-SIPHON VAULT PER DETAIL 1/C14
  - CONNECT TO OUTFALL STRUCTURE PER DETAIL 1/C18
  - CONNECT TO EXISTING STEEL COUPLING
  - RECONSTRUCT LEVEE EMBANKMENT WITH LEVEE FILL MATERIAL
  - INSTALL RSP PER DETAIL 1/C15
  - REPLACE AGGREGATE SURFACE PER DETAIL 4/C18
  - LOCATION OF ALL EXISTING UTILITIES ARE APPROXIMATE IN PLAN AND PROFILE AND ARE BASED ON THE BEST AVAILABLE UTILITY MAPPING PROVIDED BY UTILITY OWNERS. THE CONTRACTOR IS RESPONSIBLE TO FORTHOLE ALL EXISTING UTILITIES IN CONDUCT WITH THE PROJECT IN ADVANCE OF CONSTRUCTION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR DAMAGE TO ANY EXISTING UTILITIES SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR



REVISIONS DESCRIPTION DATE BY		FIELD BOOK 0000	BENCH MARK DESCRIPTION: ELEV. 36.95 MARKED: M.L. & WISER	SCALE: H. 1" = 10' V. 1" = 5'	ON ORIGINAL SCALE DRAWING ADJUST IF THIS DOES NOT SCALE AT 1"	DRAWN BY: E. JUEVA DATE: 09/19/20	CHECKED BY: A. SMITH DATE: 09/21/21	R.C.E. NO. 08602	DATE: 09/21/21
<b>CITY OF SACRAMENTO</b> <b>DEPARTMENT OF UTILITIES</b>									
IMPROVEMENT PLANS FOR <b>PUMP OUTFALLS REPLACEMENT PROJECT - B</b> <b>SUMP 155</b> <b>PLAN AND PROFILE 1 - 36" WSP</b>									
65% SUBMITTAL									



- NOTES:
- 1 REMOVE AND DISPOSE OF EXISTING 42" CMP AND APPURTENANCES FROM STA -0+46.7 TO STA 0+70.3 PER DETAIL 2/C19
  - 2 INSTALL 42" RCP FROM STA -0+46.7 TO STA 0+70.3 PER DETAIL 2/C19
  - 3 INSTALL GATE RISER STRUCTURE PER DETAIL 1/C17
  - 4 INSTALL GATE RISER PER DETAIL 1/C19
  - 5 CONNECT TO PROPOSED GATE RISER STRUCTURE
  - 6 CONNECT TO OUTFALL STRUCTURE PER DETAIL 1/C18
  - 7 CONNECT TO EXISTING VAULT
  - 8 RECONSTRUCT LEVEE EMBANKMENT WITH LEVEE FILL MATERIAL
  - 9 INSTALL RSP PER DETAIL 1/C18
  - 10 REPLACE AGGREGATE SURFACE PER DETAIL 4/C17
- LOCATION OF ALL EXISTING UTILITIES ARE APPROXIMATE IN PLAN AND PROFILE AND ARE BASED ON THE BEST AVAILABLE UTILITY MAPPING PROVIDED BY UTILITY OWNERS. THE CONTRACTOR IS RESPONSIBLE TO POthOLE ALL EXISTING UTILITIES IN CONFLICT WITH THE PROJECT IN ADVANCE OF CONSTRUCTION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR DAMAGE TO ANY EXISTING UTILITIES SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.





PN: W14130615  
PUMP OUTFALLS REPLACEMENT PROJECT

65% SUBMITTAL


REVISIONS DESCRIPTION DATE BY	BENCH MARK DESCRIPTION: MONTEC. M.L. & WISER	FIELD BOOK 0000 SCALE: H. 1"=10' V. 1"=5'	CITY OF SACRAMENTO DEPARTMENT OF UTILITIES DESIGNED BY: E. JUEVA DRAWN BY: B. GIBSON CHECKED BY: A. SMITH DATE: 09/19/20 R.C.E. NO. 09049 DATE: 03/31/21	IMPROVEMENT PLANS FOR PUMP OUTFALLS REPLACEMENT PROJECT - B SUMP 155 PLAN AND PROFILE 2 - 42" RCP	DRAWING NO. 1675 SHEET NO. 15 DATE 09/19/20
--	--	---	---	---	--






- NOTES:
- REMOVE AND DISPOSE OF EXISTING 36" WSP AND APPURTENANCES FROM STA -0+56.5 TO STA 1+16.8 PER DETAIL 2/C19
  - INSTALL 36" WSP FROM STA -0+56.5 TO STA 0+74.2 PER DETAIL 3/C19
  - INSTALL 36" FL X FL KNEE GATE VALVE
  - INSTALL COMBINATION ANTI-SIPHON AND AIR RELIEF VALVE PER DETAIL 3/C15
  - INSTALL ANTI-SIPHON VAULT PER DETAIL 1/C14
  - CONNECT TO OUTFALL STRUCTURE PER DETAIL 1/C18
  - CONNECT TO EXISTING STEEL COUPLING
  - RECONSTRUCT LEVEE EMBANKMENT WITH LEVEE FILL MATERIAL
  - INSTALL RSP PER DETAIL 1/C15
  - REPLACE AGGREGATE SURFACE PER DETAIL 4/C18

⑩ LOCATION OF ALL EXISTING UTILITIES ARE APPROXIMATE IN PLAN AND PROFILE AND ARE BASED ON THE BEST AVAILABLE UTILITY MAPPING PROVIDED BY UTILITY OWNERS. THE CONTRACTOR IS RESPONSIBLE TO POthOLE ALL EXISTING UTILITIES IN CONDUCT WITH THE PROJECT IN ADVANCE OF THE CONSTRUCTION OF THE PROJECT TO AVOID ANY DAMAGE TO ANY EXISTING UTILITIES SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR



<b>REVISIONS</b> DATE BY DESCRIPTION		FIELD BOOK 0000	BENCH MARK DESCRIPTION: ELEV. 36.95 MARKED, INL. & WISER	ON ORIGINAL SCALE DRAWING ADJUST IF THIS DOES NOT SCALE AT 1"	CITY OF SACRAMENTO DEPARTMENT OF UTILITIES	IMPROVEMENT PLANS FOR PUMP OUTFALLS REPLACEMENT PROJECT - B SUMP 155 PLAN AND PROFILE 3 - 36" WSP	65% SUBMITTAL DATE NO. 08/13/21 SHEET NO. 16 OF 16 PN: W14130615
REVISIONS DATE BY DESCRIPTION		SCALE: H. 1"=10' V. 1"=5'	DRAWN BY: E. LITKA DATE: 09/19/20	CHECKED BY: A. SMITH DATE: 03/31/21	R.C.E. NO. 08602	DATE: 03/31/21	PN: W14130615





- NOTES:
- CUT 48"x7" OPENING IN FIXED ALUMINUM GRATING FOR 42" KNIFE GATE VALVE.
  - CUT 42"x7" OPENING IN FIXED ALUMINUM GRATING FOR 36" KNIFE GATE VALVE.

FIELD BOOK 0000 SCALE: H. 1"=10' V. _____		ELEV. _____ BENCH MARK DESCRIPTION: _____	
REVISIONS DATE BY DESCRIPTION		CITY OF SACRAMENTO DEPARTMENT OF UTILITIES DESIGNED BY: E. IJUEVA DRAWN BY: B. JENSEN CHECKED BY: A. SMITH R.C.E. NO. 09049 DATE: 09/15/20 R.C.E. NO. 08502 DATE: 03/31/21	
IMPROVEMENT PLANS FOR PUMP OUTFALLS REPLACEMENT PROJECT - B SUMP 155 VAULT DETAIL		65% SUBMITTAL	
PN: W14130615 SHEET NO. 17 OF 17		PN: W14130615 SHEET NO. 30 OF 30	






- NOTES:
1. DETAILS FOR CAST IN PLACE STRUCTURE ARE SHOWN ON STRUCTURAL DRAWINGS; GATE RISER STRUCTURE MAY BE PRECAST AS AN ALTERNATIVE.
  2. HINGED COVER SHALL HAVE TORSION ASSIST PER SPECIFICATION 05 50 00.



SUMP 155 GATE RISER STRUCTURE DETAIL 1  
1/2"=1'-0"



SECTION A-A  
NTS




SECTION B-B  
NTS


REVISIONS DESCRIPTION DATE BY		BENCH MARK DESCRIPTION: ELEV.		FIELD BOOK 0000 SCALE:		CITY OF SACRAMENTO DEPARTMENT OF UTILITIES DESIGNED BY: B. JENSEN DRAWN BY: E. JUEGA CHECKED BY: A. SMITH DATE: 09/21/22 DATE: 09/19/20 DATE: 03/31/21		IMPROVEMENT PLANS FOR PUMP OUTFALLS REPLACEMENT PROJECT - B SUMP 155 GATE RISER ACCESS DETAIL AND SECTIONS		65% SUBMITTAL DRAWING NO. 19 SHEET NO. 30 PN: W14130615	
----------------------------------	--	----------------------------------	--	------------------------------	--	---	--	---	--	--	--

**GENERAL NOTES:**

1. LINE POSTS SHALL BE MIN 2 1/2" O.D. SPACED AT MAX 10' O.C.
2. HORIZONTAL BRACE AND TOP RAIL SIZE SHALL BE MIN 1 1/2" DIA.
3. END, CORNER, AND GATE POSTS SHALL BE MIN 2 1/2" O.D. WITH 1 1/2" O.D. BRACE RAIL. 3/8" TRUSS ASSEMBLY, 12-GAUGE TENSION BANDS SECURED AT MAX 12" O.C.
4. GATE FRAME SHALL BE FABRICATED FROM 2 1/2" O.D. OR 2 1/2" SQUARE MEMBERS WELDED AT ALL CORNERS.
5. CHAIN LINK FABRIC SHALL BE SECURED TO LINE POST AND TOP RAIL USING 9-GAUGE TIE WIRE SPACED AT MAX 12" O.C.
6. 2-3/8" SHOULDERS EYE BOLT 3" LENGTH TO ANCHOR TENSION WIRE PER 10' SECTION EVENLY SPACED, SECURED WITH HOG RING CAPTURING FENCE FABRIC SYSTEM.
7. PROVIDE "CITY UTILITY FACILITY - NO TRESPASSING" SIGNAGE GATE.




CORNER DETAIL **2**  
NTS




RIGHT SWING FOOTING DETAIL **1**  
NTS

GATE ANTI-SWING FOOTING DETAIL **1**  
NTS



SIDE VIEW DETAIL **4**  
NTS



MAINTENANCE GATE DETAIL **5**  
NTS

GATE OPERATOR SECTION **A**  
NTS

**8 FOOT HIGH CHAIN LINK FABRIC WITH ANGLED OUTRIGGER AND 3 STRAND BARB WIRE (OUTSIDE) STANDARD FENCING DETAIL**

REVISIONS	DATE	BY	DESCRIPTION

BENCH MARK DESCRIPTION:	ELEV.:

FIELD BOOK	0000
SCALE:	
DATE:	


**CITY OF SACRAMENTO**  
DEPARTMENT OF UTILITIES




DESIGNED BY: E. INTEA  
CHECKED BY: A. SMITH  
DATE: 09/21/22  
P.C.E. NO. 08852  
DATE: 03/31/21

IMPROVEMENT PLANS FOR:  
**PUMP OUTFALLS REPLACEMENT PROJECT - B**  
MISCELLANEOUS VAULT SECURITY DETAILS

PN: W14130615  
SHEET NO. 70  
65% SUBMITTAL




PIPE CONNECTION DETAIL **1**




PIPE CONNECTION DETAIL **2**

NOTES:  
 1. PROVIDE HAND HOLES AS NEEDED TO INSTALL FIELD LINING. WELD HAND HOLE CLOSED WHEN COMPLETE. HAND HOLES NOT REQUIRED AT OUTLETS IF ACCESSIBLE THROUGH FLAP GATE.



OUTFALL STRUCTURE CONNECTION DETAIL **1**



CROWN SURFACING DETAIL **4**

REVISIONS	DATE	BY	ELEV.
DESCRIPTION			

FIELD BOOK  
 0000  
 SCALE:  
 ON ORIGINAL SCALE  
 DRAWING ADJUST  
 IF THIS DOES NOT  
 SCALE AT 1"

BENCH MARK  
 DESCRIPTION:  
 ELEV.:

CITY OF SACRAMENTO  
 DEPARTMENT OF UTILITIES

DESIGNED BY: B. JENSEN  
 DRAWN BY: E. JUEGA  
 CHECKED BY: A. SMITH  
 DATE: 09/19/20  
 DATE: 03/21/22  
 R.C.E. NO. 09049  
 R.C.E. NO. 08502

IMPROVEMENT PLANS FOR  
 PUMP OUTFALLS REPLACEMENT PROJECT - B  
 MISCELLANEOUS DETAILS I

65% SUBMITTAL

PN: W14130615  
 SHEET NO. 30














**NOTES**

1. SEE DWG S1 & S2 FOR GENERAL NOTES.
2. SEE DWG S3 FOR TYPICAL DETAILS.
3. SEE DWG S6 FOR SECTIONS.
4. SEE OTHER CONSULTANT DWGS FOR UTILITIES THAT WILL AFFECT FITS & COMPLY W/ TYPICAL DETAILS.



**CYS**  
 CIVIL ENGINEERING  
 1000 J Street, Sacramento, CA 95811  
 (916) 441-1111  
 www.cys-engineering.com

**CITY OF SACRAMENTO**  
 DEPARTMENT OF UTILITIES  
 1000 J Street, Sacramento, CA 95811  
 (916) 441-1111  
 www.cityofsacramento.gov

CYS Job No. 20054  
 THESE DRAWINGS ARE PRELIMINARY  
 AND ARE SUBJECT TO CHANGE WITHOUT  
 NOTICE. THE USER SHALL VERIFY THE  
 CURRENT RECORD.

65% SUBMITTAL  
 DATE: 03/15/22  
 SHEET NO. 30  
 PROJECT: PUMP OUTFALLS REPLACEMENT PROJECT - B  
 DRAWING TITLE: FOUNDATION & FRAMING PLANS  
 SUMP 155

IMPROVEMENT PLANS FOR:  
**PUMP OUTFALLS REPLACEMENT PROJECT - B**  
**FOUNDATION & FRAMING PLANS**  
**SUMP 155**

**CITY OF SACRAMENTO**  
 DEPARTMENT OF UTILITIES

DESIGNED BY: B. JENSEN  
 CHECKED BY: A. SMITH  
 DATE: 03/15/22  
 R.C.E. NO. 038612

DRAWN BY: E. JUTERA  
 DATE: 09/15/20  
 R.C.E. NO. 038649

NO.	REVISIONS	DATE	BY	ELEV.

FIELD BOOK: 0000  
 SCALE: 1" = 3/8" = 1'-0"  
 ON ORIGINAL SCALE  
 DRAWING ADJUSTED  
 TO THIS SCALE  
 IF THIS DOES NOT  
 SCALE AT 1"







**Attachment C – Categorical Permission Checklist**  
*(Pressurized Pipe)*

## Categorical Permission Alteration Description – 16. Pressurized Pipes

The categorical permission covers the installation, modification, and replacement of pressurized pipes that comply with certain terms and conditions. Particularly, all pressurized pipes must be designed and installed in accordance with current USACE standards. The total area of disturbance, including staging and access areas, must not exceed 5 acres. Pressurized pipes must also be designed to prevent, (1) flotation from uplift, (2) scour or erosion, (3) damage from debris on the waterside, particularly during flood flows, (4) leakage, (5) seepage along proposed pipes, (6) corrosion, and (7) damage from vehicular loads.

All new pressurized pipes should go up and over the levee DWSE. Pressurized pipes passing over or within the freeboard zone of a levee (i.e., above the levee DWSE), should be made of metal, preferably ductile iron or coated steel, suitable for use with flexible couplings.

Backfill under and around (to 1 foot over) the proposed pipe must be controlled low-strength material (CLSM). Pipes that pass above the DWSE must have 2 feet of cover (low permeability or CLSM) to prevent damage by vehicles and equipment. Cover material on the levee crown must be placed at a ratio of 10H:1V, in the upstream/downstream direction of the levee. Pipes on the sides of the levee should be covered with a minimum of 1 foot of low permeability material, compacted in 4- to 6-inch lifts or CLSM to protect them from debris during high water (waterside) or to keep them from interfering with or being damaged by operations or maintenance of the levee (landside). Fill must be free of deleterious materials and construction debris and placed in 4- to 6-inch-thick loose lifts and compacted to not less than 95% of the maximum density at moistures between -2 and +3 percent of optimum moisture content obtained from ASTM D698 (USACE preferred method), or alternately, 90% of the maximum density at moistures between -2 and +3 percent of optimum moisture content obtained from ASTM D1557. At the sponsor and levee maintaining agency's discretion, pipes on the levee slopes may be left exposed.

Only suitable material must be used as levee fill materials. Fill must be free from: roots and other organic matter, contaminated hazardous or toxic material, trash, debris, and frozen materials. Satisfactory fill material must have a plasticity index between 8 and 25, have a liquid limit less than 45, a minimum fines content of 20%, and 100% passing the 3-inch sieve.

Pressurized pipes terminating in the channel require a positive closure device on the waterside that is accessible from the levee crown. Pressurized pipes transporting product completely across or through the federal project easement require positive closure devices located landward of any levees and channel. The positive closure device shall be located within one mile on both sides of the federal project. If the invert of the pipe is over the levee crown, the combination of a pump station on the waterside and a siphon breaker is considered an appropriate means of closure. Pipes located within or beneath a levee must have watertight joints that can accommodate movements resulting from settlement.

All pressurized pipes that cross the levee foundation at a depth less than or equal to two times the height of the levee should be evaluated for uplift. Pipes crossing the surface of the levee must be designed to counteract buoyancy forces of an empty pipe, with water at the DWSE.

Pressurized pipelines running parallel to flood risk management projects should be located at least 15 feet beyond the levee toes. Pipe location and orientation must be clearly marked in the field so they can be easily identified for flood fighting crews.

If appropriate, the requester should prepare an excavation plan demonstrating the effects of excavation on the stability of the embankments.

The site layout should provide adequate access for maintenance vehicles to refill fuel tanks and service/replace pumps, generators, etc. Pressurized pipes must also allow easy access for rapid closure in the event of leakage or rupture.

No plastic pipes (HDPE, PVC, etc.) are allowed in the levee embankment or its foundation unless they are embedded in concrete.

If an electrochemical or chemical reaction between the substratum or groundwater and pipe materials is expected, the pipe and pipe couplings must be protected.

After installation of pressurized pipes, the requester must demonstrate 0% pipe leakage in pipes in the levee. Pipes must be pressure tested to industry standards. Pipes must be regularly inspected, including the interior, if possible, looking for signs of maintenance issues. If an inspection indicates corrosion, alignment sag or heave, or separation at joints, corrective action must be taken as soon as possible to avoid failure. Pipe valves must be periodically inspected and pressure tested to ensure that they are functioning properly. Pressure tests must show no significant loss in pressure. Leaks and other deficiencies must be addressed as soon as possible. All replacement parts must be of equivalent or better quality than those being replaced.

The preferred method for abandoning pipes that pass through or over a levee is complete removal. If removal is not feasible, the pipes and other structures may be filled with a cement/bentonite-based grout or flowable fill. The grout needs to be sufficiently fluid so that it can be pumped to completely fill the pipe leaving no voids.

### Categorical Permission Alteration Checklist – 16. Pressurized Pipes

*Note:* The following checklist is intended for planning purposes only, and includes information that USACE reviewers look for when considering a Section 408 request for pressurized pipes under the Categorical Permission. To be reviewed under the Categorical Permission, the proposed project must adhere to all requirements of the Categorical Permission, including the full alteration description (see previous page). The plans and narrative project description should reflect this information.

1.	<input type="checkbox"/> New Construction	<input checked="" type="checkbox"/> Replacement	<input type="checkbox"/> Modification	<input type="checkbox"/> Authorize Existing
2.	Maximum total area of disturbance is 5 acres:	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
	Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]			
	Comment: <u>Area of disturbance is 0.07 acre.</u>			
3.	Pipes are designed to prevent flotation from uplift, scour or erosion, damage from debris on the waterside (particularly during flood flows), seepage along proposed pipes, corrosion, leakage, and damage from vehicular loads:	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
	Reference: <u>Refer to detail 3 on sheet 41.</u>			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
4.	Backfill under and around (to 1 foot over) the proposed pipe must be controlled low-strength material (CLSM):	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
	Reference: <u>Refer to detail 3 on sheet 41</u>			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
5.	Pipes passing over the DWSE will have a minimum of 2 feet of cover (low permeability or CLSM):	Yes <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>	
	Reference: <u>Refer to profiles on sheets 14-16 in Bid Set B</u>			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
6.	If material must be added to the levee crown, the added material must be sloped at a ratio of 10H:1V horizontal to vertical, in the upstream/downstream direction to prevent a “speed bump” effect and facilitate vehicle access:	Yes <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>	
	Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
7.	Fill will be compacted to at least 95% of maximum density as determined by ASTM D698, between -2 and +3% of optimum moisture content:	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
	Reference: <u>Refer to Spec section 31 00 00 3.6B.</u>			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
8.	Satisfactory fill material must have a plasticity index between 8 and 25, have a liquid limit less than 45, a minimum fines content of 20%, and 100% passing the 3-inch sieve:	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
	Reference: <u>Refer to Spec section 31 00 00 2.2A.</u>			
	Comment:			
9.	All fill will be free of organics or other inappropriate materials:	Yes <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>	
	Reference: <u>Refer to Spec section 31 00 00 3.9.B.1.6.</u>			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			

10.	Pipes terminating in the channel have a positive closure device on the waterside that is accessible from the levee crown:	Yes <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>
	Reference: <u>Refer to profiles on Sheets 14-16 and Detail 6 on Sheet 18 in Bid Set B</u>		
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]		
11.	Pipes transporting product completely across the federal project have a positive closure devices located within 1 mile on both sides of the federal project:	Yes <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>
	Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]		
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]		
12.	Pipes located within or beneath a levee have watertight joints that can accommodate movements resulting from settlement:	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
	Reference: <u>Refer to detail 2 on Sheet 40</u>		
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]		
13.	Pipes crossing the surface of the levee are designed to counteract buoyancy forces of an empty pipe, with water at the DWSE:	Yes <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>
	Reference: <u>Refer to detail 3 on sheet 41</u>		
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]		
14.	Pipe location and orientation will be clearly marked in the field:	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
	Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]		
	Comment: <u>Pipe location and orientation can be identified by vault structure and outfall location</u>		
15.	Pipes will allow easy access for rapid closure:	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
	Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]		
	Comment: <u>Positive valve closures on the levee crest will ensure easy access for rapid closure</u>		
16.	Plastic pipes within the levee embankment or its foundation are embedded in concrete:	Yes <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>
	Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]		
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]		
17.	If a chemical or electrochemical reaction is expected, the pipe and pipe couplings must be protected:	Yes <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>
	Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]		
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]		
18.	Any work within the levee embankment or foundation?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
	Reference: <u>Detail 1 on Sheet 22 in Bid Set B</u>		
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]		
19.	Any work ≤50 feet beneath the channel invert?	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>
	Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]		
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]		
20.	Hydraulic blockage calculation ≥1%?	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>
	Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]		
	Comment: <u>Rip Rap cross-sectional area below ordinary high watermark is anticipated to be significantly less than the cross-sectional area of the American River and therefore negligible.</u>		
21.	Hydraulic model used for hydraulic analysis?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
		N/A <input checked="" type="checkbox"/>	



**Reference:** [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]

**Comment:** [ Click to enter rationale, explanation, unique situation, etc. ]

– For Official Use Only below this line –

*Comment*

### CP Eligibility Review

<u>Yes</u>	<u>No</u>	<u>Add'l. Info Requested</u>		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Environmental Reviewer: _____	Date: <small>Click date</small> _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Engineering Reviewer: _____	Date: <small>Click date</small> _____

**Attachment D – Categorical Permission Checklist**

*(Gravity Pipe)*

### **Categorical Permission Alteration Description – 13. Gravity Pipes**

The categorical permission covers the installation, modification, and replacement of gravity pipes and culverts that comply with certain terms and conditions. The total area of disturbance, including staging and access areas, must not exceed 5 acres.

Generally, cast-in-place reinforced concrete pipes are preferable for gravity lines where considerable settlement is expected. No plastic pipes are allowed in the levee embankment or its foundation unless they are embedded in concrete or encased in a steel conduit with the annular space completely grouted.

Backfill under and around (to 1 foot over) the proposed pipe must be controlled low-strength material (CLSM).

Suitable material must be used as levee fill materials. Fill must be free from: roots and other organic matter, contaminated hazardous or toxic material, trash, debris, and frozen materials. Satisfactory fill material must have a plasticity index between 8 and 25, have a liquid limit less than 45, a minimum fines content of 20%, and 100% passing the 3-inch sieve.

Fill must be free of deleterious materials and construction debris and placed in 4- to 6-inch-thick loose lifts and compacted to not less than 95% of the maximum density at moistures between -2 and +3 percent of optimum moisture content obtained from ASTM D698 (USACE preferred method), or alternately, 90% of the maximum density at moistures between -2 and +3 percent of optimum moisture content obtained from ASTM D1557.

Pipe joints must have sufficient flexibility to adjust under expected settlement and stretching of the pipe. Pipes should be designed to counteract uplift of the empty pipe at the design high water stage. If a chemical or electrochemical reaction is expected, the pipe and pipe couplings must be protected.

All new and existing gravity-flowing culverts must have a flap gate on the waterside end with provisions for positive closure (slide gate or sluice gate). The slide gate or sluice gate should be housed in a gatewell at the waterside edge of the levee crown to provide access.

Internal inspections must occur to ensure the pipes are in good condition. Video inspection of the internal condition of the pipe or pressure testing should be undertaken at least once every five years. Valves and gates should be periodically inspected and tested to ensure they are functioning properly. If the inspection indicates corrosion, alignment sag or heave, or separation at joints, corrective action must be taken as soon as possible. In most cases, once a pipe begins to oval or flatten at the crown or has lost more than 5% of its original interior height, it should be replaced.

Periodically, debris must be removed and corrosion or other damage on trash screens repaired.

If maintenance indicates that pipe replacement is necessary, all replacement parts must be of equivalent or better quality than those to be replaced. All repairs must restore pipes and associated equipment to the standards of the original design, or better.

### Categorical Permission Alteration Checklist – 13. Gravity Pipes

*Note:* The following checklist is intended for planning purposes only, and includes information that USACE reviewers look for when considering a Section 408 request for gravity pipes under the Categorical Permission. To be reviewed under the Categorical Permission, the proposed project must adhere to all requirements of the Categorical Permission, including the full alteration description (see previous page). The plans and narrative project description should reflect this information.

1.	<input type="checkbox"/> New Installation	<input checked="" type="checkbox"/> Replacement	<input type="checkbox"/> Modification	<input type="checkbox"/> Authorize Existing
2.	Maximum total area of disturbance is 5 acres: <span style="float: right;"><input checked="" type="checkbox"/></span>			
	Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]			
	Comment: <u>Area of disturbance is 0.07 acre.</u>			
3.	Plastic pipes within the levee embankment or foundation will be embedded in concrete or encased in a steel conduit with the annular space completely grouted: <span style="float: right;">Yes <input type="checkbox"/> N/A <input checked="" type="checkbox"/></span>			
	Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
4.	Pipe joints will have sufficient flexibility to adjust under the expected settlement and stretching of the pipe: <span style="float: right;"><input checked="" type="checkbox"/></span>			
	Reference: <u>Detail 3 on Sheet 21 (Bid Set B)</u>			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
5.	Backfill under and around (to 1 foot over) the proposed pipe must be controlled low-strength material (CLSM): <span style="float: right;"><input checked="" type="checkbox"/></span>			
	Reference: <u>Refer to detail 3 on sheet 41</u>			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
6.	Fill will be compacted to at least 95% of maximum density as determined by ASTM D698, between -2 and +3% of optimum moisture content: <span style="float: right;"><input checked="" type="checkbox"/></span>			
	Reference: <u>Refer to Spec section 31 00 00 3.6B.</u>			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
7.	Satisfactory fill material must have a plasticity index between 8 and 25, have a liquid limit less than 45, a minimum fines content of 20%, and 100% passing the 3-inch sieve: <span style="float: right;"><input checked="" type="checkbox"/></span>			
	Reference: <u>Refer to Spec section 31 00 00 2.2A.</u>			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
8.	All fill will be free of organics or other inappropriate materials: <span style="float: right;"><input checked="" type="checkbox"/></span>			
	Reference: <u>Refer to Spec section 31 00 00 3.9.B.1.6.</u>			
	Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
9.	New and existing gravity-flowing culverts will have a flap gate on the waterside end with provisions for positive closure: <span style="float: right;">Yes <input checked="" type="checkbox"/> N/A <input type="checkbox"/></span>			
	Reference: <u>Detail 1 on Sheet 21 in Bid Set B</u>			
	Comment: <u>42" CMP pipe</u>			

- Continued on next page -

10. If a chemical or electrochemical reaction is expected, the pipe and pipe couplings must be protected:	Yes <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>	
Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]			
Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
11. Any work within the levee embankment or foundation?	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	
Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]			
Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			
12. Hydraulic blockage calculation $\geq 1\%$ ?	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	N/A <input type="checkbox"/>
Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]			
Comment: <u>Rip Rap cross-sectional area below ordinary high watermark is anticipated to be significantly less than the cross-sectional area of the American River and therefore negligible.</u>			
13. Hydraulic model used for hydraulic analysis?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	N/A <input checked="" type="checkbox"/>
Reference: [ Click to enter document source. Example – plan sheet (p. 4), specs, report. ]			
Comment: [ Click to enter rationale, explanation, unique situation, etc. ]			

– For Official Use Only below this line –

[ Comment ]

**CP Eligibility Review**

<u>Yes</u>	<u>No</u>	<u>Add'l. Info Requested</u>		Date: <small>Click date</small>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Environmental Reviewer: _____	_____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Engineering Reviewer: _____	_____